

VIEW WITH DOOR REMOVED

NOTES


1. IT IS RECOMMENDED TO TERMINATE LOAD CELL INSTRUMENT CABLE AND ALL OTHER I/O DIRECTLY INTO PLUG-IN TERMINALS ON GT500E.
2. POWER SUPPLY IS SUPPLIED DISCONNECTED AND SHOULD BE CONNECTED AT TIME OF COMMISSIONING ONCE 24VDC POWER IS CONFIRMED.

OPTIONAL 240VAC	6	2	8GX12G BUTTON HD PHILLIPS SCREW	8GX12BPHS
	5	1	POWER SUPPLY 240VAC/24VDC	PS00079A1
	4	1	DIN RAIL 200MM	PS00053A1
	3	4	8GX12G BUTTON HD PHILLIPS SCREW	8GX12BPHS
	2	1	GT500E CONTROLLER 24VDC	PS0021401
	1	1	400x400x200 GR304 STN. STL. CABINET	PS0058001
ITEM	QTY	DESCRIPTION	PART/DRG NO.	

**TC** TC PROCESS EQUIPMENT  
 COPYRIGHT THRIVE CONSULTING  
 PTY. LTD, SYDNEY AUSTRALIA. NO  
 PART OF THIS DRAWING MAYBE  
 REPRODUCED WITHOUT PERMISSION

TITLE  
 GT500E CONTROLLER CABINET  
 400x400x200 IP65 304 STN STL  
 WITH DOOR WINDOW

DRAWN	RHS	16.06.17
CHECKED	JRH	17.07.17
ENG. MGR.	TWF	17.07.17
APPR'D	MAA	17.07.17



DRG No.  
 PS0060001

SCALE 1:5

REVISION 0

A3